

TRAMFLOC, INC.

P. O. Box 350, Tempe, AZ 85280-0350 Voice: 480-491-6895 Fax: 480-456-1664

Technical Information Bulletin

TRAMFLOC® 1244 PHOSPHATE CORROSION & SCALE INHIBITOR FOR POTABLE WATER

Product Description

Tramfloc® 1244 contains a high ratio of poly to ortho phosphate formulated with linear chain complex phosphate and ortho-phosphate blends which are applied to help control corrosion and scaling in potable water systems, equipment and metallurgy. Tramfloc® 1244 Inhibitor is manufactured under strictly sanitary conditions and use high quality food grade condensed inorganic phosphate feed stocks. This product is so carefully formulated that it resists reversion for well more than one year. Tramfloc® 1244 Inhibitor is completely water soluble and is UL® approved for the treatment of potable, food process, and membrane feed waters.

Uses

Tramfloc® 1244 Inhibitor effectively sequesters calcium, iron, copper, lead, and manganese to help prevent mineral scale deposits and control corrosive attack in water distribution systems. The correct application of Tramfloc® 1244 Inhibitor results in the gradual elimination of carbonate deposits, red water, black stains, lead and copper excursions, and green spotting complaints.

Feeding

It is recommended that the product be fed continuously either neat or diluted with soft water to a point of turbulent flow well before chlorination. If your plant applies lime-soda softening, Tramfloc® 1244 Inhibitor may be fed either before or after the clarifier or filter. If your treatment process includes an iron removal process, feed the product after the filter and before post-chlorination. Your Tramfloc representative can establish the proper control testing protocol for your system or plant.

Packaging

Tramfloc® 1244 Inhibitor is available in drums, IBC's and bulk.

Handling and Storage

Solutions should be made-down and diluted in stainless steel, FRP or plastic vessels. Aluminum components should be avoided. Make-down water temperatures should be between 60-95° F. Tramfloc® Inhibitor containers should be stored completely closed in a cool, dry place.

Safety and Health

Spills of this chemical are slippery. Precautions should be taken to prevent them from entering lakes or streams. Chemical can be flushed with copious amounts of water and disposed of according to local regulations or treated with an absorbent material, then collected for subsequent legal disposal. Always wear protective safety equipment and prevent contact of chemical with skins, eyes, and clothing. Observing basic industrial hygiene precautions should prevent any health or safety hazards.

The above data is based upon information Tramfloc, Inc. believes reliable and is supplied for informational purposes only. Tramfloc, Inc. disclaims any liability for damage or injury which results from the use of the above data and nothing contained herein shall constitute a guarantee, warranty (including warranty of merchantability or fitness for a particular purpose) or representation (including freedom from patent liability) by Tramfloc, Inc. with respect to the accuracy or completeness of the data, the product described, or their use for any specific purpose even if that purpose is known to Tramfloc, Inc. The final determination of the suitability of the information, the manner of use of the information or product and potential infringement of patents is the sole responsibility of the user.